

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 9660-1572:100

CATEGORY: LP Gas Shut-Off Valve

LISTEE: *Advanced Safety Technologies, 3921 Sandstone Dr., El Dorado Hills, CA 95762
Contact: Jimmy Hershberger (916) 941-6700 Fax (916) 939-0912

DESIGN: Models SCV-1 and SCV-1B automatic resetting excess flow valve. The unit is a one-inch brass bodied valve intended for use as gas line service valves suitable for LP-Gas and natural gas where the maximum working pressure does not exceed 5 psig. Refer to listee's data sheet for additional detailed product description and operational considerations. Connection sizes:

1" NPT (Inlet) x 1" (outlet)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For vertical installation only.

MARKING: Listee's name, model number, rating and CSA label.

APPROVAL: Listed as natural and LP-gas excess flow shut-off valve for use in gas line at pressure not in excess of 5 psig.

NOTE: These units are not motion sensitive valve. This valve is not equivalent to, nor is it to be substituted for, any required manual shut-off valve for the building gas supply.

*Formerly 9660-1562:100

*10-09-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager